



NOTES

- 1.) UNITS MUST BE ATTACHED TO IN-PLANT COMPRESSED AIR SUPPLY FOR CLEANING MECHANISM TO FUNCTION (80 MAX psig CLEAN DRY AIR)
- 2.) WELDED STEEL CONSTRUCTION OF 12 Gd. MILD STEEL.
- 3.) FINISH: INDUSTRIAL GRADE CRIMSON RED INSIDE & OUT.
- 4.) DUST TRAY CAPACITY: 1.75 CUBIC FT.
- 5.) INLET COLLAR SIZES 6 IN. 8 IN.

SPECIFICATIONS

TOTAL VALVES, 1
 TOTAL CARTRIDGES, 2
 COMPRESSED AIR 1.0 SCF @80psi per sec.

FILE RP2 SPECIFICATION				TOLERANCES UNLESS OTHERWISE SPECIFIED 3 DEC. PLACES +/- .00 4 DEC. PLACES +/- .000 ANGLES 1/2° UNLESS NOTED OTHERWISE		 METAL-FAB FABRICATORS & WELDERS VICTORIA, B.C. CAN.	
DWG. BY MC	DATE 2-2-98	CHKD. BY JJ	DRW 11	SH. 1 OF 1	DWG. NO. L1582	REV. 1	